


Villavent® DUO
type TSL-2



N Montasjeanvisning
GB Installation instructions

N FORORD

Villavent as har produsert og levert utstyr for boligventilasjon i en årrekke. Anleggene er installert i tusenvis av hjem, både i Norge og i utlandet.

Selv om vi har brukt all vår erfaring i utviklingen av Villavent-utstyret, avhenger det endelige resultatet også av riktig prosjektering, installasjon og vedlikehold. Studer derfor denne anvisningen nøyde før arbeidet påbegynnes.

Produsent og forhandler er ikke ansvarlig for skade på utstyr eller brann som kan oppstå fordi etterfølgende instruksjoner ikke er fulgt.

N INNHOLDSFORTEGNELSE

Montering av vifteenheten	side	3
Alt.1 - Montering i ventilatorskap	side	4
Alt.2 - Montering bak krydderhytte	side	4
Alt.3 - Montering i overskap	side	5
Plassering av festeskruer i vifteenheten	side	4
Skaptipassing	side	5
Elektrisk tilkobling	side	3
Ventiler	side	4
Avtrekkventiler	side	4
Overstrømning fra rom til rom	side	5
Frisklufttilførsel	side	4
Ildsted	side	4
Kanaler	side	4
Utstyrsoversikt	side	5

N MONTERING AV VIFTEHENETEN

Villavent Duo type TSL-2, er en unik kombinasjon av kjøkkenventilator og vifte for sentralavtrekk i mindre boliger og boligheter. Vifteenheten monteres over komfyren og tilkobles kanaler med avtrekk fra WC og våtrom. Avkast av bruk luft skjer fortrinnsvis over tak via Villavent takhatt. De to ekstra avtrekksåpningene på toppen av vifteenheten kan blendes, og viften vil dermed fungere som en ekstra kraftig kjøkkenventilator.

NB! Vifteenhetens underkant må ikke monteres lavere enn 47 cm over komfyr.

GB INTRODUCTION

Villavent as has manufactured equipment for domestic ventilation for many years. The systems are installed in thousands of buildings both in Norway and abroad.

All our experience has been put into the development of the Villavent ventilation systems, but the final result depends on the quality of the total planning, installation and maintenance. Therefore this instruction manual must be carefully studied before the installation.

The manufacturer and the distributors will not be responsible for damage on equipment or fire caused by insufficient installation.

GB INDEX

Installing the exhaust fan	page	3
Alt.1 - Installation in ventilation cupboard	page	4
Alt.2 - Installation to spice rack	page	5
Alt.3 - Installation in kitchen cupboard	page	3
Mounting fixing screws in the fan unit	page	4
Adjusting to cupboard	page	4
Electrical connection	page	3
Louvres	page	4
Extract louvres	page	5
Circulation of air between rooms	page	3
Fresh air supply	page	4
Fireplace	page	4
Ducting	page	5
Equipment list	page	5

GB INSTALLATION OF THE FAN UNIT

Villavent Duo type TSL-2 is a unique combination of kitchen ventilator and extract fan for central extract in houses and apartments. The fan unit is installed over the cooker and is connected to the duct system for extract from WC, bathroom and laundry room. Discharge of stale indoor air is discharged via Villavent roof unit or wall grill. The two extra spigots on top of the fan unit can be blanked off, and the ventilation unit will then function as a powerful kitchen ventilator with extract only from the cooking area.

NOTE! Ensure the distance between cooker hob (electrical) and cookerhood filters is at least 47 cm. (60 cm for the UK market).




Fig. 1

Alternativ 1. Montering i ventilatorskap

Vifteenheten festes til ventilatorskapet med 4 stk. skruer (4,5x16 mm, "F" i fig. 1). Bruk vedlagt hullmal (sjablon) til å merke av festehullene.

Hullmalen legges først på skapets høyre innerside, slik at malens side, som er merket "A", sammenfaller med bakveggen i skapet. Bor opp pkt. 1 og 2, avmerket på malen. Bor deretter opp venstre sides festehull på samme måte. Festene bores opp med Ø2 mm bor.

NB! Dersom kjøkkeneskapene har 20 mm veggtynnelse, må de 2 distanseklykkene på hver side av vifteenheten fjernes.

Alternativ 2. Montering til krydderhytte

Festepunktene på hvert sideskap må føres ut 16 mm, eller tilsvarende veggtynnelse i et ventilatorskap. Fremgangsmåte for øvrig som beskrevet i alt. 1.

Alternativ 3. Montering i overskap

Det må lages en passende utsparing i bunnen av skapet. Fremgangsmåte for øvrig som beskrevet i alt. 1.




Fig. 2

N

PLASSERING AV FESTESKRUER I VIFTEENHETEN

Vifteenheten skrus fast til overskap fra innsiden etter at filterplaten "H" (fig.2) først er løsnet. Filterplaten løsnes ved å skyve plastlåsene "L" (fig. 2) mot hverandre

Skaptipassing

Uansett montasjealternativ skal alltid skapfront være i flukt med vifteenhetens uttreksdel, når denne er innskjøvet.

Tilpassing gjøres ved å løsne skruene "M" og skyve de firkantede platene "P" til riktig posisjon. Lås til slutt ved å skru til skruene "M" igjen (fig. 3).

Alt. 1: Installation in ventilation cupboard

The fan unit is fixed to the ventilation cupboard by means of 4 screws (4,5x16 mm "F" on fig. 1). Use the enclosed template to mark off the points for the fixing holes.

First hold the template towards the right inner side of the ventilation cupboard, so that the template side marked "A" fits against the back wall. Drill holes marked 1 and 2 on the template. Then drill the holes on the left inner side of the cupboard. Use a Ø2 mm drill bit.

NOTE! If the cupboard walls are 20 mm thick, the 2 spacers on the sides of the fan unit must be removed.

Alt. 2. Installation to spice rack

Mounting instructions as in alt 1, but the space between the side walls and the ventilation unit must be filled in (16 mm).

Alt. 3. Installation in kitchen cupboard

A suitable opening has to be made in the bottom of the cupboard. Further installation instructions as for alt.1.




Fig. 3

GB

MOUNTING FIXING SCREWS IN THE FAN UNIT

Remove filter, "H" (fig. 2) by pushing the 2 filter locks inwards. Screw the ventilation unit to the cupboard walls from the inside. Loosen filterplate by pushing the filter locks "L" inwards.

Adjusting to cupboard

The depth of the unit can be varied to match the facia cover flush with the cupboard front, with the extendable sectors in the pushed-in position.

Adjust stop position by loosening the screws "M" and push the plates "P" to correct position. Remember to tighten the screws "M" after the adjustment (fig. 3).

N

ELEKTRISK TILKOBLING

Vifteenheten leveres med ledning og jordet støpsel (rundstift 10/16A), og skal bare tilkobles en 10A eller 16A /230 V jordet stikkontakt.

GB

ELECTRICAL CONNECTION

The ventilation unit is supplied with cable and earthed plug for connection to mains supply (10 A or 16 A/230V. For the UK market 13 A/240 V).




Fig. 4



Fig. 5




Fig. 6




Fig. 7

N

VENTILER

Avtrekksventiler (fig. 4).

Avtrekksventiler plasseres på WC og våtrom (bad, vaskerom etc.). Ventilene festes i rammer, slik at de enkelt kan tas ut for rengjøring i varmt såpevann

NB! Ventilene bør plasseres i tak og lengst mulig vekk fra døråpning.

NB! Ventilkjerne åpnes for grunninnstilling 10 omdr. fra stengt stilling og låses med sentermutter.

Overstrømninger fra rom til rom (fig. 5).

For å oppnå tilfredsstillende luftsirkulasjon i boligen, må det sørges for overstrømningsmuligheter fra oppholdsrom (stue, soverom, etc.) til rom med avtrekk (kjøkken, WC, våtrom, etc.).

Benytt f.eks. dører med spalte i karm, terskelfrie dører eller overstrømningsventiler i dør eller vegg.

Frisklufttilførsel (fig. 6).

En forutsetning for god ventilasjon er at det er samsvar mellom ønsket avtrekksluftmengde og frisklufttilførsel. Det må derfor monteres vindu med spalteventiler eller monteres egne veggventiler i oppholdsrom (soverom, stue etc.). Friskluften tilføres fortrinnsvis i soner med liten fare for trekk.

Det må monteres egen frisklufttilførsel for ildsted, tørketrommel etc.

Ildsted (fig. 7).

Er boligen utstyrt med ildsted, må det sørges for tilstrekkelig tilgang på forbrenningsluft (fortrinnsvis til samme rom).

Peis og annet åpent ildsted har behov for tilførsel av 150 - 300 m³/h luft. Dette tilsvarer samlet uteluftåpninger på minst 300 cm²

GB

LOUVRES

Extract louvres (fig. 4).

Mount extract louvres in bathroom, WC and laundry room. Fix the louvres in frames to ease the removing for cleaning in warm soapy water

NOTE! The louvres should preferably be mounted in the ceiling and as far away from the door opening as possible.

NOTE! Set the opening of the louvres by turning the core 10 revolutions from closed position. Fix by tightening the centre locking nut.

Circulation of air between rooms (fig. 5).

It is important to ensure satisfactory air circulation in the house, i.e. between living areas and rooms with extract points (kitchen, WC, laundry room etc)

Use doors with a slot/gap in the frame (top or bottom), doors without door sill (min. 70 cm² free area per extract diffuser) or slots/vents in doors/wall.

Fresh air supply (fig. 6).

In order to ensure satisfactory ventilation of your home, fresh outdoor air, corresponding to the amount of air extracted from the dwelling, must be supplied through slots or vents in window frames or outer walls (in bedrooms, living areas etc.). Supply the fresh air into zones with a minor fear of draught.

Install a separate fresh air supply for fireplace, tumble dryer etc.

Fireplace (fig. 7).

Ensure that there is a sufficient supply of outdoor air to rooms with an open fireplace. This is to avoid backdraught through the chimney.


To ensure sufficient exhaust of fumes and smoke through chimney, 150 - 300 m³/h of fresh air (outdoor air) must be supplied to the room. This corresponding to a total of 300 cm² slot or vent openings in outer walls.

N**KANALER (fig. 8).**

Det legges opp avtrekkskanaler fra WC og våtrom, og avkastkanal over tak fra vifteenheten



GB**DUCTING (fig. 8).**

Install extract ducts from WC, bathroom and laundry room and discharge air via roof or wall grill



- A) Villavent Duo med 2 - 4 stk. avtrekksventiler
- B) Villavent Duo med 1 - 2 stk. avtrekksventiler
- C) Villavent Duo som ekstra kraftig kjøkkenventilator

- A) Villavent Duo with 2 - 4 pcs. extract louvres
- B) Villavent Duo with 1 - 2 pcs. extract louvres
- C) Villavent Duo installed as a powerful kitchen ventilator



- 1) Overgang fra vifteenhet til kanalstusser
- 2) Skruer for feste av overgang
- 3) Kanalstusser
- 4) Styretapper for kanalstusser
- 5) Skruer for feste av kanalstusser
- 6) Blindplate
- 7) Styretapper for blindplate
- 8) Skruer for feste av blindplate
- 9) Endebunn for kanalstuss

- 1) Connector from fan unit to spigot
- 2) Screws for fixing of connector
- 3) Spigots (male)
- 4) Indication pins for spigots
- 5) Screws for fixing of spigots
- 6) Blanking plate for extract opening
- 7) Indication pins for blockage plate
- 8) Screw for fixing of blockage plate
- 9) Bung for spigot

Prinsipp for tilkobling av kanalanlegg. Kanaler må isoleres mot kondens ved montasje i kalde rom

Principle of connection to duct system. Ducting must be well insulated when installed in cold rooms.

Fig. 8

N
FØLGENDE REGLER MÅ FØLGES:

- For avkastkanal over tak benyttes dimensjon Ø125 mm. For resterende kanaler benyttes dimensjon Ø100 mm.
- Kanaler bør alltid legges opp så kort og rett som mulig.
- Kanaler som monteres på kaldt loft eller i uoppvarmede rom, må være isolert for å unngå kondensering (vanligvis 30 mm isolasjonstykke).
- Avkastluft må ikke slippes ut i røykkanal, men ledes ut over tak via takhatt.
- Avtrekksventiler monteres i ventilrammer eller ventilringer.

NB! Plassering av avkastrist/takhatt må tilfredsstille krav fra den lokale bygningskontrollen.

GB
THE FOLLOWING RULES MUST BE FOLLOWED:

- Use Ø125 mm duct for discharge air. For the remaining duct runs, use Ø100 mm ducts.
- All duct runs should be installed as short and straight as possible.
- Ducts installed in cold areas (rooms), must be well insulated to avoid condensation (normally 30 mm insulation thickness).
- Exhaust air must not be discharged into a flue which is used for exhausting fumes etc., but must always be lead to atmosphere.
- Extract louvres must be mounted into frames.

NOTE! Wall grill or roof unit must be mounted in accordance with the local building regulations.





Fig. 9

Det er viktig at det ikke slurves med montering og installasjon av anlegget.





Skader og feil, som f.eks. defekte kanaler, dårlig festede kanaler, manglende eller dårlig isolerte kanaler/kanaldele osv., vil redusere ventilasjonseffekten, og kan dessuten resultere i vannskader pga. kondensering
Under monteringsarbeidet kan det være nyttig å notere seg følgende tips:

- a) Komprimerte, fleksible kanaler kan med fordel trekkes ut på forhånd (maks. lengde = 3,0 m), dvs. før tilkobling til det øvrige kanalnettet.
- b) Spirokanaler kan isoleres med isolasjonsstrømpe før montasje.
- c) Kanaldele sammenkobles med skjøtenipler.
- d) Fleksible kanaler kappes med kniv eller saks, og spirokanaler med metallsag.
- e) Kanalanlegg og isolasjon festes sammen med kanaltape, men for spirokanaler benyttes det også selvborende skruer (3 stk pr. skjøt). Tilkobling til vifteenhets utføres ofte ved hjelp av slangeklemmer.

It is of vital importance that the installation of the system is made in accordance with these instructions.

Damage and faults such as defective ducting, missing or insufficient fixing of ducts or insufficient insulation on duct runs/duct connections etc. will reduce the efficiency of the ventilation system and could also lead to leakage due to condensation. During the installation it could be useful to note the following:

- a) Compressed, flexible ducts could be pulled to full length before connection to the duct system. (max. length = 3 m).
- b) Insulate spiro ducts before the installation.
- c) Connect T-pieces etc. to duct connectors before the installation.
- d) Use a knife or a pair of sissors to cut aluminium ducts and a metal saw to cut spiro ducts.
- e) On a flexible duct system, a special tape is used to secure the insulation to the duct/connectors. For a spiro duct system, use self drilling screws (3 per connection). Use hose clips to connect the ducts to the spigots on the ventilation unit.

	N UTSTYRSOVERSIKT	GB EQUIPMENT LIST
	Duo type TSL-2, vifteenhet.	Duo type TSL-2, fan unit.
	Takhatt, Ø125 mm.	Roof unit, Ø125 mm.
	Fleksible alu.kanaler, uisolerte/ isolerte, Ø100 og 125 mm.	Flexible alu.ducts, plain/ insulated, Ø100 and 125 mm.
	Spirokanaler, Ø100 og 125 mm.	Spiro ducts, Ø100 and 125 mm.
	Isolasjonsstrømpe for spiro kanaler, 30 mm, Ø100 og 125 mm.	Insulation sleeving for spiro ducts, 30 mm, Ø100 and 125 mm.
	Fleksibel lydfellekanal, Ø100 og 125 mm. Lengde 1 m.	Flexible sound attenuators, Ø100 and 125 mm. Length 1 m.
	Skjøtenipler med og uten pakning, Ø100 og 125 mm.	Duct connectors with and without rubber seal, Ø100 and 125 mm.
	Skjøtemuffer, Ø100 og 125 mm.	Duct connectors, Ø100 and 125 mm.
	Endebunn, Ø100 mm.	Bung, Ø100 mm.
	T-rør, Ø100/100 mm.	Tee piece, Ø100-100 mm.
	Bend 45 og 90°, Ø100 og 125 mm.	Bend 45 and 90°, Ø100 and 125 mm.
	Veggbend 90°, Ø100 mm.	Wall bend 90°, Ø100 mm.
	Avtrekksventil med ventilramme, Ø100 mm type VLF.	Extract louvre with frame, Ø100 mm type VLF.
	Montasjemateriell som f.eks. kanaltape, spiroskruer, slange- klemmer, båndjern og montasje- anvisning.	Installation material i.e. tape, spiro screws, hose clips, duct fixing band and installation instructions.

N

Rett til endringer forbeholdes.

GB

Specifications may be changed
without notice.

Produsent/Manufacturer:



Luramyrveien 38
P.b. 293
N-4303 SANDNES

Tlf.: + 47 51 96 97 00
Fax: + 47 51 96 97 99

Address in UK:
Villavent Ltd.
Avenue 2
Station Lane Industrial Estate
OXON, OX8 6YD

Tel.: (01993) 77 22 70
Fax: (01993) 77 99 62

Forhandler/Distributor: